UK DECLARATION OF CONFORMITY

| Manufacturer's Name: | Prodrive Technologies N.E. B.V. |
|-------------------------|---|
| Manufacturer's Address: | Science Park Eindhoven 5501, 5692 EM Son, The Netherlands |

This declaration of conformity is issued under the sole responsibility of the manufacturer.

| Product: | AC Charger |
|----------|----------------------|
| Model: | WLAC2-xxxxxxxxxxxXVX |

The product described above is in conformity with the relevant statutory requirements. Conformity is ensured with reference to the relevant designated standards used or other technical specifications in relation to which conformity is declared:

Radio Equipment Regulations 2017 No.1206

| Safety and Health | EMC | Radio |
|----------------------------------|----------------------------|-----------------------|
| EN IEC 61851-1:2019 ¹ | EN IEC 61851-21-2:2021 | EN 300 328 V2.2.2 |
| EN IEC 62368-1:2020 + A11:2020 | EN 301 489-1 V2.2.3 | EN 301 908-1 V15.2.1 |
| EN IEC 62311:2020 | EN 301 489-3 V2.3.2 | EN 301 908-13 V13.2.1 |
| EN 62479:2010 | Draft EN 301 489-17 V3.2.5 | EN 301 511 V12.5.1 |
| | EN 301 489-52 V1.2.1 | EN 300 330 V2.1.1 |

The Approved Body Cetecom Inc. (No. 8502) performed a Module B conformity assessment procedure and issued Type Examination Certificate No. UK24-0011-02-TEC.

Measuring Instruments Regulation 2016 No. 1153²

| EN 50470-1: 2006 | CLC/TR 50579 |
|------------------|--------------|
| EN 50470-3: 2006 | WELMEC 7.2 |

The Approved Body NMi Certin UK (TIC) Ltd. (No. 8506) performed a Module B conformity assessment procedure and issued Type Examination Certificate No. T12409-UK-1. Module D assessment was performed by NMi Certin B.V. (0122) and issued Certificate No. CE-383.

Restriction of the Use of Certain Hazardous Substances Regulations 2012 No. 3032 as amended EN IEC 63000:2018

Additional information:

- ¹ EN IEC 61851-1:2019 is applied except for Clause 8.4 which states that "For Modes 3 and 4 permanently connected EV supply equipment, protective earthing conductors shall not be switched." This clause conflicts with the requirements of the UK's IET Wiring Regulations BS 7671:2018+A2:2022 Section 722 for Electric Vehicle Charging Installations, which permits the switching of protective conductors under certain conditions. BS 7671:2018 +A2:2022 Section 722.411.4.1 is followed.
- ² Conformity to the MIR is applicable for the following model: WLAC2-x07xxxxMxxUx

Signed for and on behalf of: Prodrive Technologies N.E. B.V.

Name, function: Signature: Nilles Vrijsen, Technical Director

Place and date of Issue:

Mlles Unjsen EAC5FBF4E48A42D... The Netherlands 26 November 2024