

# EU-type examination certificate

Number **T12409** revision 3  
Project number 3860453  
Page 1 of 1

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the Measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Prodrive Technologies N.E. B.V.  
Science Park Eindhoven 5501  
5692 EM Son  
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter integrated in an EV Charging System**

Type : WLAC1-.... WLAC2-....  
Manufacturer's mark or name : Prodrive Technologies  
Reference voltage : 3x 230/400 V or 230 V  
Reference current : 5 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +55 °C

Further properties are described in the annexes:

- Description T12409 revision 3;
- Documentation folder T12409-3.

Initially issued 23 December 2022

Valid until 23 December 2032

Remark This revision replaces the previous versions, including the documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
17 October 2024

Certification Board

**NMI Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMI Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

